GOVERNMENT OF BIHAR

P. H. Division , Begusarai,Teghra

DISTRICT LEVEL DRINKING WATER TESTING LABORATORY, BEGUSARAI.

Report No. :- WQ/ 01/ 2007 -2026-27- 92 **Dt.** 24.06.2026

Ref No -RTSV/L-11/2026-27 Date 22.06.2026

Agency :- RTS Vidyapeeth Begusarai, Bihar

Type Of Sample:- Treated Water Sample

Date of Sampaling -22.06.2026

Sampal recieved on -22.06.2026

Source of Sample :- Boring

Sample Collected by - School Staff

PHYSICO-CHEMICAL Water TEST REPORT

Sl. No.	Location	Physico - Chemical Parameters (mg/l) ppm												
		pH	Turbidity	Test	TDS	Total Hardness	Calcium	Magnesium	Chloride	Alkalanity	Iron	Colour	Arsenic	Fluoride
1	RTS Viidyapeeth, Begusarai	7.4	1	Agreeable	189	246	55	19	59	220	0.39	>5	BDl	0.63
Desirable Limit*		6.5-8.5	5 NTU	Agreeable	500mg/l	300mg/l	75mg/l	30mg/l	250mg/l	200mg/l	1.0mg/l		0.01mg/l	1.0mg/l
Permissible Limit* in absence of alternate source		NR	NR	Not Agreeable	2000mg/l	600mg/l	200mg/l	100mg/l	1000mg/l	600mg/l	NR		NR	1.5mg/l

---------- END of Report----------

*(1) Drinking Water Specification 2ND Revision -IS:10500:2012,

*(2) BDL = Below Detection Limit,

*(3) Testing Methods are taken by APHA 20th Edition.

*(4) NR = No Relaxation

This Water is Safe to Drink

ATTESTED

Supriya Bharti

Manager

RTS Vidyapeeth

Begusarai-851101

ATTESTED

PRINCIPAL

RTS VIDYAPEETH, BEGUSARAI

24.06.26

Lab Incharge(DLWTL)

P.H.Division Begusarai

District Level Water Testing Laboratory

P.H. Division Begusarai

Shekhar/E/Lab/2012

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 302 Dated: 03/06/2026

It is certified that an inspection team headed by Sanjay Kumar, Lab Incharge (Name of Officers with designation) from Charge P.H. Division, Begusarai (Name of Department/ Office) inspected the **RTS VIDYAPEETH, RITLAL SINGH ROAD, BEHIND G.D. COLLEGE, BEGUSARAI, BIHAR- 851101** (Name & Address of the school) on 25/05/2026 (date of inspection Time 11:30 A.M. and found that the **RTS VIDYAPEETH, RITLAL SINGH ROAD, BEHIND G.D. COLLEGE, BEGUSARAI, BIHAR- 851101** has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 02/06/2027

Executive Engineer
P.H. Division, Begusarai

Signature with Seal: .....

Name : Sri Manikant Kumar

Designation : Executive Engineer

Name & Address of the Office / Department: PH. Division, Begusarai PHED Bihar

To
The Principal
RTS VIDYAPEETH
RITLAL SINGH ROAD, BEHIND G.D. COLLEGE,
BEGUSARAI, BIHAR- 851101

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

ATTESTED
Supriya Bharti
Manager
RTS Vidyapeeth
Begusarai-851101

ATTESTED
Toni Kumari
PRINCIPAL
RTS VIDYAPEETH, BEGUSARAI